


NOTE 1: CONTRACTOR TO BURY 2 RUNS OF 4" SCHEDULE 40 PVC 4 FEET DEEP TO BASE OF UTILITY POLE. STUB CONDUIT OUT AT GROUND LEVEL. INSTALL A PULL STING IN ONE RUN OF CONDUIT.

NOTE 2: REFERENCE UVG-LOCATION DRAWING FOR TRANSFORMER CLEARANCE FROM A STRUCTURE.

			
75-500 KVA TRANSFORMER PAD DETAIL			
DRAWN	CHECK	DATE	FILE NAME
CLJ	JLJ	07-27-16	TRANS_PAD_DETAIL-B
SCALE	SHEET	ASSEMBLY	
NOT TO SCALE	1 OF 1		