



### WRONG LOCATION TO SET METER POLE




### CORRECT LOCATION OF METER POLE




POLE MUST BE WITHIN 30 FEET OF ANY EXTERIOR WALL OF THE MOBILE HOME AND MUST BE VISIBLE FROM MOBILE HOME

### WRONG LOCATION TO SET METER POLE




### CORRECT LOCATION OF METER POLE



POLE MUST BE WITHIN 30 FEET OF ANY EXTERIOR WALL OF THE MOBILE HOME AND MUST BE VISIBLE FROM MOBILE HOME


### METER CLEARANCES



THE WORKING CLEARANCE AROUND THE METER SHALL HAVE A DEPTH OF 3', A WIDTH OF 30", AND A HEIGHT OF 6'-6".

CAUTION: NO GAS METERS WITHIN 3' RADIUS OF METER ENCLOSURE.

### CLEARANCE FROM POWER LINES TO MOBILE HOME



15 FOOT BOUNDARY LINE TO NEAREST SPEPA POWER LINE MEASURED HORIZONTALLY. THE ONLY LINES THAT MAY ENTER THIS ZONE IS THE SERVICE LINE TO THE METER POLE.

NO ELECTRIC WIRES ARE PERMITTED TO CROSS OVER MOBILE HOME. MOBILE HOMES ARE NOT PERMITTED TO BE INSTALLED UNDER ELECTRIC LINES.

LOCAL CODE AUTHORITIES MAY HAVE REQUIREMENTS IN ADDITION TO THOSE SHOWN.



### METER POLE LOCATION FOR OVERHEAD SERVICE TO MOBILE HOME

|          |                      |              |        |           |               |
|----------|----------------------|--------------|--------|-----------|---------------|
| DATE     | REVISION             | DRAWN        | CHECK  | DATE      | FILE NAME     |
| 08/18/16 | CHANGED COMPANY LOGO | CLJ          | JLJ    | JAN. 2016 | LOC. OH TO MP |
|          |                      | SCALE        | SHEET  | ASSEMBLY  |               |
|          |                      | NOT TO SCALE | 1 OF 1 |           | N/A           |